

Annexure C/

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 12/08/2025

It is certified that an inspection team headed by Dr. Rakshita Singh, Block Development Officer, Jamalpur, Mirzapur from PHED inspected the Sunbeam Academy Knowledge Park, Baraipur, Jamalpur, Mirzapur on 03/08/2025 (date of inspection) and on the basis of Water Test Report (Attached) dated 12/08/2025 (PHED Lab) certified that the Sunbeam Academy Knowledge Park has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 11/08/2029

Signature with Seal:

Name

: Dr. Rakshita Singh

Designation

: Block Developing Officer,
Jamalpur, Mirzapur

Name & Address of the Office / Department :

To

Sunbeam Academy Knowledge Park

Baraipur, Jamalpur, Mirzapur

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

64 /

Secretary
Sunbeam Academy
Knowledge Park
Baraipur, Jamalpur

Principal
SUNBEAM ACADEMY
KNOWLEDGE PARK
No.-2133184
CODE-711
690800404
BARAIPUR

WATER TEST REPORT

SAMPEL SOURCE: SUNBEAM ACADEMY, KNOWLEGDE PARK, MIRZAPUR

TEST PROTOCOL: POTABLE WATER TEST

1. TURBIDITY	:	< 5 NTU
2. COLOUR	:	Colourless
3. TASTE & ODOUR	:	Un Objectionable
4. pH VALUE	:	7.4
5. TOTAL DISSOLVED SOLIDS	:	85 ppm.
6. CHLORIDES	:	08 ppm.
7. SULPHATES	:	Nil
8. FLUORIDE	:	Nil
9. NITRATES	:	1ppm
10. NITRITES	:	Nil
11. CALCIUM	:	20ppm.
12. MAGNESIUM	:	15ppm.
13. TOTAL HARDNESS AS CaCO ₃	:	40ppm.
14. IRON	:	0.02ppm.
15. RESIDUAL CHLORINE	:	Nil (R.O. Treated water)

Observations: All parameter suits to best potable water limits.

CONCLUSIVE RESULT: Sample was found to be fit for potable use

Signature with 
21/1/2015
2003 1000/1000
MIRZAPUR, MIRZAPUR


Secretary
Sunbeam Academy
Knowledge Park
Baraipur Mirzapur